



RIVERSIDE COUNTY FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL
CITY OF LAKE ELSINORE



130 S. Main St. • Lake Elsinore, California 92530
(951) 674-3124 Ext. 225 • Dbloom@Lake-Elsinore.Org

Special Event Conditions for Booths

The following conditions shall be met at all times during the event. The recipient of these conditions shall distribute to any and all participants that these conditions may apply to. Any activity that is not performed within these conditions will be charged a \$168.00 per/hr. standby charge back billed to the vendor and may result in the closure of the booth.

Conditions

1. **Portable fire extinguishers-** Portable fire extinguishers shall be installed in the following locations. Install a portable fire extinguisher, with a minimum rating of 2A-10BC, for every 75 feet of travel distance. **VENDOR AREA:** Each vendor shall a minimum of one fire extinguisher per exhibit/sales booth in an accessible area. Extinguishers must have current CSFM service tags affixed; or within one year of from the date of month and year of manufacture.
2. **Electrical Wiring-** Electrical wiring shall be in accordance with the National Electrical Code. This includes but is not limited to the use of UL listed electrical cords, proper protection for circuits, and the use of no more than 1 multi-receptacle device per circuit.
3. **Food Service Areas-** Fire and life safety requirements shall be applicable for all food services areas,
 - a. **Flammable & Combustible liquids-** The use, storage and handling of any flammable or combustible liquid shall be subject to approval Location of use and storage of any flammable or combustible liquid shall be noted on the plans prior to approval.
 - b. **LPG Cylinders-** The use and storage of portable containers of Liquefied Petroleum Gas (LPG) tents is subject to approval. Location of use and storage of any portable container of LPG shall be noted on the plans prior to approval. All cylinders must be secured to prevent tipping or falling over. Tanks shall be separated from tents by no less than 10'.
 - c. **Commercial Cooking-** Commercial cooking shall not be conducted outside of the designated areas and shall be conducted only with approved equipment. Fire department approval shall be obtained prior to use.
 - d. **Cooking Separation-** Designated cooking areas shall be separated by not less than 10' from non-cooking booths and 20' from tents.
4. **Generators-** Generators and other internal combustion power sources shall be separated from temporary membrane structures and tents by a minimum of 20 ft. and shall be protected from contact by fencing, enclosure, or other approved means. Fire Extinguishers rated not less than 2A-20BC shall be located adjacent to the generators in case of fire.

