



GROUP DELTA

AGUILAR CONSULTING, INC.
2155 Chicago Avenue, Suite 301
Riverside, CA 92507

December 21, 2017
Project No. IR-617

Attention: Ceazar Aguilar, PE
President

SUBJECT: Impact of Revised Bridge Length on Preliminary Foundation Report
Temescal Canyon Road Bridge (Replace)
Bridge No. 56C-0050
Lake Elsinore, California

Dear Ceazar:

We understand that the bridge length and configuration has been modified as summarized in the following table:

Design Parameter	306' Long Bridge	375' Long Bridge
No. of Span	3	3
Bridge Length	306'	375'
Span Dimension	90.5'-125'-90.5'	110'-155'-110'
Structure Depth	5'	5.75' at the abutments that will taper to 7.25' near the pier/bent
Pier Column Diameter	5'	6'

The change does not affect the preliminary conclusions and recommendations provided in Group Delta's Preliminary Foundation Report (PFR) dated August 26, 2016.

Sincerely
GROUP DELTA CONSULTANTS, INC.

Curt Scheyhing, PE, GE
Principal Geotechnical Engineer

